



# Pt. Prithi Nath (P.G.) College

(Affiliated to C.S.J.M. University, Kanpur)

96/12, Mahatma Gandhi Marg, Kanpur - 208 001

Website : www.ppncollege.org • e-mail : ppncollegekanpur@gmail.com



Ref. No. PPNPGC/Roof Repair/1-2026

Dated 18/04/2026

## Tender Notice

**Brick Coba** -Providing and laying integral cement based water proofing treatment including preparation of surface as required for treatment of roofs, balconies, terraces etc consisting of following operations:

- Applying a slurry coat of neat cement using 2.75 kg/sqm. of cement admixed with water proofing compound conforming to IS. 2645 and approved by Engineer-in-charge over the RCC slab including adjoining walls up to 300 mm height including cleaning the surface before treatment.
- Laying brick bats with mortar using broken bricks/brick bats 25 mm to 115 mm size with 50% of cement mortar 1:5 (1 cement: 5 coarse sand) admixed with water proofing compound conforming to IS: 2645 and approved by Engineer-in-charge over 20 mm thick layer of cement mortar of mix 1:5 (1 cement :5 coarse sand) admixed with water proofing compound conforming to IS: 2645 and approved by Engineer-in-charge to required slope and treating similarly the adjoining walls up to 300 mm height including rounding of junctions of walls and slabs.
- Finishing the surface with 20 mm thick joint less cement mortar of mix 1:4 (1 cement: 4 coarse sand) admixed with water proofing compound conforming to IS: 2645 and approved by Engineer in charge including laying fiber cloth of approved quality in top layer of plaster and finally finishing the surface with trowel with neat cement slurry and making pattern of 300x300 mm square 3 mm deep. And filling of expansion joint with baker rod with polysulphide/silicon.
- The whole terrace so finished shall be flooded with water for a minimum period of two weeks for curing and for final test. All above operations to be done in order and as directed and specified by the Engineer-in-Charge: With average thickness of 120 mm and minimum thickness at khurra as 65mm. area approx 6400 sq. ft.

### **Eligibility:**

- The Contractor should have experience Civil Work.
- The Contractor must possess valid **GST registration** and **PAN**
- EMD Rs. 10000.00 in shape Demand Draft in favor of PPN College Form forwarding Account**

### **Terms & Conditions:**

- Payment will be made only after satisfactory work and quality verification.
- The college reserves the right to accept or reject any or all tenders without assigning any reason.
- Material (Cement & Chemical) must be use best quality and branded
- Work must be completed within 02 months from issue of purchase order. After 02 months 01% deducted per week of bill value
- Security 10% bill of value will be hold for 01 year
- If any portion of building will damage by the contractor except assign repair work area. It will repaired by the contractor.

### **Submission:**

Sealed tenders should reach the **Office of the Principal** by **01 May 2026 up to 5:00PM.**

Tenders will be opened on **02/05/2026 at 3:00 PM.**

  
Principal

PT. PR THI NATH (P.G.) COLLEGE  
KANPUR